

Important Safety Notice

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to full testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to.

Terminals, including factory fitted, should be checked periodically to ensure correct tightness.

DO NOT USE POWER TOOLS ON THESE PRODUCTS




Bureau Veritas KEMA Certified EN 60947-1 & 3 Compliant IP65





| Data | Range | Units | LB1603PNLME LB1603PSNME | LB2003PNLME LB2003PSNME | LB2503PNLME LB2503PSNME |
|--|-------|-----------------|----------------------------|----------------------------|----------------------------|
| Rated thermal current I_{th} at 50°C | Amps | A | 160 | 200 | 250 |
| Rated insulation voltage U_i | Volts | V | 1000 | 1000 | 1000 |
| Rated dielectric strength | Volts | kV | 4 | 4 | 5 |
| Rated impulse voltage U_{imp} | Volts | kV | 8 | 8 | 8 |
| Rated operational current I_e at 400V AC-22 | Amps | A | 160 | 200 | 250 |
| Rated operational current I_e at 400V AC-23 | Amps | A | 160 | 160 | 160 |
| Rated operational power P_e at 400V AC-23 | Watts | kW | 89 | 89 | 89 |
| Rated breaking capacity | Amps | A | 1280 | 1280 | 1280 |
| Rated making capacity | Amps | A | 1600 | 16000 | 1600 |
| Rated short circuit making capacity (peak value) I_{cm} | Amps | kA | 13 | 13 | 13 |
| Rated short-time withstand current (1 sec) I_{cw} | Amps | kA | 7 | 7 | 7 |
| Minimum number of mechanical operations | - | Cycles | 30,000 | 30,000 | 30,000 |
| Minimum number of electrical operations @ 400V AC-23 | - | Cycles | 1,000 | 1,000 | 1,000 |
| Terminal Capacity (rigid copper cable) | - | mm ² | 95 | 120 | 120 |
| Lug bolt size | - | - | - | M10 | M10 |
| Maximum size of busbar connection | - | mm | - | 5x30 | 5x30 |
| Tightening torque | - | Nm | 4 | 13 | 13 |

Enclosure Dimensions



Terminal Configuration






Handle Assembly:

1. Ensure that the handle is in the off position and locate the handle on to the door with the handle showing the off position at 9 o'clock



2. Tighten the four M5 flange nuts to 1.5Nm



Shaft Assembly:


3. Ensure that the switch is in the off position and fully insert the shaft into the switch with the cross pin in a horizontal position

4. Tighten the M5 shaft grub screw to 1.2Nm using a 2.5mm A/F allen key




Fuse Shroud Assembly: (SWITCH FUSE ONLY)

5/6. Install the four upright shrouds into the corresponding clips



7. Install fuse shroud into the corresponding clips

Padlock Operation:



Door Interlock Defeat Mechanism (For Authorised Personnel Only):

⚠ WARNING! ACCESS TO LIVE PARTS

- Ensure that the door is closed and the handle is in the on position
- Locate the hole on the right side of the handle, then push and hold a small pin into the hole to activate the defeat mechanism
- The door can now be opened in the on position. Remove pin and close the door to reset the mechanism

