
# Rako RCM100 Wall-Plates: Installation, Programming and Operating Instructions

### General

RCM100 Wall-plate electronics module is a wireless 10 button wall mounted control panel providing 7 Scenes plus Off and Master Raise and Lower. The unit provides full scene programming.





The Rako RCM series of wall-plates are designed to cope with a number of different installation situations. These are predominantly:


Flush fixing into a UK back-box.

Surface mounting with a UK back-box (not screwless).

Surface mounting with no back-box or onto a European DIN standard or French box (Euro module).

In order to fit the wall-plate it requires a fixing kit which is supplied separately. Fixing kits are available with a number of faceplate finishes and styles. The standard flush fitting fixing kit is as follows:

White Plastic Front Plate	
Black Back Plate	
2 x 25mm M3.5 screws.	
2 x M3.5 nuts	
White pattress	
Flush Mounting Plate	
2 v 12mm M2 5 cerous	



### Checking for correct operation

Rako control panels are supplied with a pullout tab to prevent inadvertent operation and battery deterioration during transit. Slide the tab out of the battery compartment. The Rako control panel should now be operational. To check this press one of the buttons on the front of the Electronics Module and the indicating LED should illuminate briefly for a single flash. If the LED does not flash or it flashes repeatedly for a short burst (low battery warning) then you should contact Rako controls.

### Battery replacement

The Rako RCM series of wall-plates are designed to be powered by batteries. The designed battery life is better than 3 years (based on 30 button presses daily) but the batteries will eventually need replacing. In normal use the Led on the front panel illuminates momentarily when a button is pressed to indicate that a (radio) transmission has been made. When the batteries are approaching the end of their useful life the Led will continue to blink after a button has been pressed. When this starts to happen the batteries should be replaced as soon as possible. *Always use two CR2016 batteries*. To replace the batteries remove the Wall Plate from the wall and unclip the Electronics Module from it's mounting plate, taking care not to damage the aerial (note that when flush mounted the aerial may be located in a hole outside the back-box). Carefully Slide out the battery compartment drawer. Replace with new batteries ensuring that the positive (+) terminal makes contact with the battery clip and the negative (-) terminal with the pad on the circuit board.


To ensure reliable operation always ensure that battery contacts and battery surfaces are kept clean of any grease, moisture or other contamination.

#### Warning

Lithium batteries may explode if handled incorrectly. Always dispose of used batteries in accordance with manufacturer's recommendations.

### Flush Fixing a Wallplate to a Back Box









#### Warning

Rako wall-plates are designed to operate at safety extra low voltages (6V). When fixing the wall-plates to existing back-boxes there may be mains wiring present, if this is the case then the wiring should be made safe, properly insulated and any metal back-boxes earthed. Earthing of the back box is essential if a decorative metal front plate is being used. Should there be any doubt in how to do this contact a qualified electrician.

Rako Controls Ltd accepts no responsibility for any damage or injury caused by incorrect installation of a Rako product.

### Surface Mounting a Wallplate using a Pattress (not screwless cover plates)











### General

Rako thanks you for having purchased a Rako product and hopes that you are pleased with your system. Should for any reason you need to contact us please contact us via our website <a href="www.rakocontrols.com">www.rakocontrols.com</a> or by phoning our customer help line on 01634 226666.

## Rako RCM100 Wall-Plates: Installation, Programming and Operating Instructions

